

AIR CHANGE GUIDE

AIR CHANGE GUIDE

COMMERCIAL	AC/H
assembly rooms	4 - 8
bakeries	20 - 30
banks	3 - 4
cafes, coffee bars	10 - 12
canteens	5 - 10
conference rooms	8 - 12
dance halls	6 - 8
entrance halls	3 - 5
hair dressing salons	10 - 15
laundries	15 - 30
lavatories	8 - 15
libraries	3 - 5
offices	4 - 8
photo dark rooms	10 - 15
recording studios	10 - 12
restaurants	6 - 10
school rooms	2 - 4

DOMESTIC	AC/H
bathroom	6 - 10
bedroom	2 - 4
cellar	4 - 8
garage	6 - 8
kitchen	10 - 15
laundry room	10 - 15
toilet	8 - 12

These values must not take the place of any regulation requirements and can be modified for particular applications.